



OMEGA TEST HOUSE

OTH/QC/RF/25

Lab : J-889, Sitapura Industrial Area, Jaipur (Raj.)-302 022

Head Office : 2/60, Malviya Nagar, Jaipur (Raj.)-302 017

Contact : 09414074020, 09829051363, 0141-2521969, Email: omegatesthouse@gmail.com

TEST REPORT

Sample Name	Sample No.C-1 Water Vikram Nagar WTP (Outlet)	Sample Code	2403839
Report No.	OTH/RN-20242487	Report Issue date	30/03/2024
ULR No.	TC733123000002487F	Page No.	01 OF 01
Reference to Sampling	NA	Sample Collected By	Customer

Customer Name & Address:		Sample Receiving Date:	22/03/2024
Siyag Builders, H-28, Kanta Khaturia Colony, Bikaner. (Raj.)		Date of Testing	23/03/2024
		Date of Completion	28/03/2024
		Sample Qty. & Condition	1 Ltr. & Ok
Environmental Conditions Under which test performed	Room Temperature	Registration No.	RAJ.1713/012971

Appearance: - Clear Colorless Liquid.

CHEMICAL ANALYSIS

S.No.	Parameters	Results	Test Method	Units	Limits IS : 10500/2012 Desirable Limit/ Rejection Limit
1.	Odor	Agreeable	IS : 3025 (P-5)	NA	Agreeable
2.	Turbidity	Nil	IS : 3025 (P-10)	NTU	1 Max./5 Max
3.	pH	8.11	IS : 3025 (P-11)	NA	6.5 to 8.5
4.	Total Dissolved Solids	220	IS : 3025 (P-16)	mg/l.	500 Max. / 2000 Max.
5.	Total Hardness as CaCO ₃	144.13	IS : 3025 (P-21)	mg/l.	200 Max./ 600 Max.
6.	Chloride as Cl	55.92	IS : 3025 (P-32)	mg/l.	250 Max./ 1000 Max.
7.	Iron as Fe	BDL(<0.01)	IS : 3025 (P-53)	mg/l.	0.3 Max./ No relaxation
8.	Fluoride as F	0.12	IS : 3025 (P-60)	mg/l.	1.0 Max./ 1.5 Max.

MICROBIOLOGICAL ANALYSIS

1.	E.coli./ 100ml	Absent/100 ml	IS : 15185-2016	Present or Absent/100 ml	Shall not be detectable in any 100ml of sample
2.	Coliform/ 100 ml	Absent/100 ml	IS : 15185-2016	Present or Absent/100 ml	Shall not be detectable in any 100ml of sample

Note: - 1. BDL- Below Detection Limit, NA- Not Applicable

2. The results relate only to items tested.

3. The information about the sample provided by customer.

END OF REPORT

Authorized Signatory
(Microbiologist)

Authorized Signatory
(Quality Manager)

NOTE:

- (1.) The result listed refer only to the tested sample and applicable parameters. Endorsement of products is neither inferred nor implied.
- (2.) Total liability of our concern is limited to the invoiced amount.
- (3.) The report is not to be reproduced wholly or in part and cannot be used as an evidence in the court of law and should not be used in any advertising media without our special permission in writing.



OTH/QC/RF/25

OMEGA TEST HOUSE

Lab : J-889, Sitapura Industrial Area, Jaipur (Raj.)-302 022

Head Office : 2/60, Malviya Nagar , Jaipur (Raj.)-302 017

Contact : 09414074020, 09829051363, 0141-2521969, Email: omegatesthouse@gmail.com

TEST REPORT

Sample Name	Sample No. C-3 Water Anu Pratap WTP (Outlet)	Sample Code	2403841
Report No.	OTH/RN-20242489	Report Issue date	30/03/2024
ULR No.	TC733124000002489F	Page No.	01 OF 01
Reference to Sampling	NA	Sample Collected By	Customer

Customer Name & Address:		Sample Receiving Date:	22/03/2024
Siyag Builders, H-28, Kanta Khaturia Colony, Bikaner. (Raj.)		Date of Testing	23/03/2024
		Date of Completion	28/03/2024
		Sample Qty. & Condition	1 Ltr. & Ok
Environmental Conditions Under which test performed	Room Temperature	Registration No.	RAJ.1713/012971

Appearance: - Clear Colorless Liquid.

CHEMICAL ANALYSIS

S.No.	Parameters	Results	Test Method	Units	Limits IS : 10500/2012 Desirable Limit/ Rejection Limit
1.	Odor	Agreeable	IS : 3025 (P-5)	NA	Agreeable
2.	Turbidity	Nil	IS : 3025 (P-10)	NTU	1 Max./5 Max
3.	pH	7.85	IS : 3025 (P-11)	NA	6.5 to 8.5
4.	Total Dissolved Solids	240	IS : 3025 (P-16)	mg/l.	500 Max. / 2000 Max.
5.	Total Hardness as CaCO ₃	148.13	IS : 3025 (P-21)	mg/l.	200 Max./ 600 Max.
6.	Chloride as Cl	53.99	IS : 3025 (P-32)	mg/l.	250 Max./ 1000 Max.
7.	Iron as Fe	BDL(<0.01)	IS : 3025 (P-53)	mg/l.	0.3 Max./ No relaxation
8.	Fluoride as F	0.24	IS : 3025 (P-60)	mg/l.	1.0 Max./ 1.5 Max.

MICROBIOLOGICAL ANALYSIS

1.	E.coli./ 100 ml	Absent/100 ml	IS : 15185-2016	Present or Absent/100 ml	Shall not be detectable in any 100ml of sample
2.	Coliform/ 100 ml	Absent/100 ml	IS : 15185-2016	Present or Absent/100 ml	Shall not be detectable in any 100ml of sample

Note: - 1.BDL- Below Detection Limit, NA- Not Applicable,

2. The results relate only to items tested.

3. The information about the sample provided by customer

END OF REPORT

Authorized Signatory
(Microbiologist)
Authorized Signatory

Authorized Signatory
(Quality Manager)
Authorized Signatory

NOTE:

- (1.) The result listed refer only to the tested sample and applicable parameters. Endorsement of products is neither inferred nor implied.
- (2.) Total liability of our concern is limited to the invoiced amount.
- (3.) The report is not to be reproduced wholly or in part and cannot be used as an evidence in the court of law and should not be used in any advertising media without our special permission in writing.



OTH/QC/RF/25

OMEGA TEST HOUSE

Lab : J-889, Sitapura Industrial Area, Jaipur (Raj.)-302 022

Head Office : 2/60, Malviya Nagar , Jaipur (Raj.)-302 017

Contact : 09414074020, 09829051363, 0141-2521969, Email: omegatesthouse@gmail.com

TEST REPORT

Sample Name	Sample No.C-4 Water Anu Tara WTP (Outlet)	Sample Code	2403842
Report No.	OTH/RN-20242490	Report Issue date	30/03/2024
ULR No.	TC733124000002490F	Page No.	01 OF 01
Reference to Sampling	NA	Sample Collected By	Customer

Customer Name & Address:		Sample Receiving Date:	22/03/2024
Siyag Builders, H-28, Kanta Khaturia Colony, Bikaner. (Raj.)		Date of Testing	23/03/2024
		Date of Completion	28/03/2024
Environmental Conditions Under which test performed		Sample Qty. & Condition	1 Ltr. & Ok
Room Temperature		Registration No.	RAJ.1713/012971

Appearance: - Clear Colorless Liquid.

CHEMICAL ANALYSIS

S.No.	Parameters	Results	Test Method	Units	Limits IS : 10500/2012 Desirable Limit/ Rejection Limit
1.	Odor	Agreeable	IS : 3025 (P-5)	NA	Agreeable
2.	Turbidity	Nil	IS : 3025 (P-10)	NTU	1 Max./5 Max
3.	pH	7.74	IS : 3025 (P-11)	NA	6.5 to 8.5
4.	Total Dissolved Solids	230	IS : 3025 (P-16)	mg/l.	500 Max. / 2000 Max.
5.	Total Hardness as CaCO ₃	140.12	IS : 3025 (P-21)	mg/l.	200 Max./ 600 Max.
6.	Chloride as Cl	50.14	IS : 3025 (P-32)	mg/l.	250 Max./ 1000 Max.
7.	Iron as Fe	BDL(<0.01)	IS : 3025 (P-53)	mg/l.	0.3 Max./ No relaxation
8.	Fluoride as F	0.18	IS : 3025 (P-60)	mg/l.	1.0 Max./ 1.5 Max.

MICROBIOLOGICAL ANALYSIS

1.	E.coli/ 100 ml	Absent/100 ml	IS : 15185-2016	Present or Absent/100 ml	Shall not be detectable in any 100ml of sample
2.	Coliform/ 100 ml	Absent/100 ml	IS : 15185-2016	Present or Absent/100 ml	Shall not be detectable in any 100ml of sample

Note: - 1.BDL- Below Detection Limit, NA- Not Applicable,

2. The results relate only to items tested.

3. The information about the sample provided by customer

END OF REPORT

Authorized Signatory
(Microbiologist)
Authorized Signatory

Authorized Signatory
(Quality Manager)
Authorized Signatory

NOTE:

- (1.) The result listed refer only to the tested sample and applicable parameters. Endorsement of products is neither inferred nor implied.
- (2.) Total liability of our concern is limited to the invoiced amount.
- (3.) The report is not to be reproduced wholly or in part and cannot be used as an evidence in the court of law and should not be used in any advertising media without our special permission in writing.



OTH/QC/RF/25

OMEGA TEST HOUSE

Lab : J-889, Sitapura Industrial Area, Jaipur (Raj.)-302 022

Head Office : 2/60, Malviya Nagar , Jaipur (Raj.)-302 017

Contact : 09414074020, 09829051363, 0141-2521969, Email: omegatesthouse@gmail.com

TEST REPORT

Sample Name	Sample No.C-5 Water Sentab WTP (Outlet)	Sample Code	2403843
Report No.	OTH/RN-20242492	Report Issue date	30/03/2024
ULR No.	TC733124000002492F	Page No.	01 OF 01
Reference to Sampling	NA	Sample Collected By	Customer

Customer Name & Address:		Sample Receiving Date:	22/03/2024
Siyag Builders, H-28, Kanta Khaturia Colony, Bikaner. (Raj.)		Date of Testing	23/03/2024
		Date of Completion	28/03/2024
Environmental Conditions Under which test performed		Sample Qty. & Condition	1 Ltr. & Ok
Room Temperature		Registration No.	RAJ.1713/012971

Appearance: - Clear Colorless Liquid.

CHEMICAL ANALYSIS

S.No.	Parameters	Results	Test Method	Units	Limits IS : 10500/2012 Desirable Limit/ Rejection Limit
1.	Odor	Agreeable	IS : 3025 (P-5)	NA	Agreeable
2.	Turbidity	Nil	IS : 3025 (P-10)	NTU	1 Max./5 Max
3.	pH	7.90	IS : 3025 (P-11)	NA	6.5 to 8.5
4.	Total Dissolved Solids	250	IS : 3025 (P-16)	mg/l.	500 Max. / 2000 Max.
5.	Total Hardness as CaCO ₃	152.14	IS : 3025 (P-21)	mg/l.	200 Max./ 600 Max.
6.	Chloride as Cl	61.79	IS : 3025 (P-32)	mg/l.	250 Max./ 1000 Max.
7.	Iron as Fe	BDL(<0.01)	IS : 3025 (P-53)	mg/l.	0.3 Max./ No relaxation
8.	Fluoride as F	0.30	IS : 3025 (P-60)	mg/l.	1.0 Max./ 1.5 Max.

MICROBIOLOGICAL ANALYSIS

1.	E.coli./ 100 ml	Absent/100 ml	IS : 15185-2016	Present or Absent/100 ml	Shall not be detectable in any 100ml of sample
2.	Coliform/ 100 ml	Absent/100 ml	IS : 15185-2016	Present or Absent/100 ml	Shall not be detectable in any 100ml of sample

Note: - 1.BDL- Below Detection Limit, NA- Not Applicable,

2. The results relate only to items tested.

3. The information about the sample provided by customer

END OF REPORT

Authorized Signatory
(Microbiologist)

Authorized Signatory
(Quality Manager)

NOTE:

- (1.) The result listed refer only to the tested sample and applicable parameters. Endorsement of products is neither inferred nor implied.
- (2.) Total liability of our concern is limited to the invoiced amount.
- (3.) The report is not to be reproduced wholly or in part and cannot be used as an evidence in the court of law and should not be used in any advertising media without our special permission in writing.



OTH/QC/RF/25

OMEGA TEST HOUSE

Lab : J-889, Sitapura Industrial Area, Jaipur (Raj.)-302 022

Head Office : 2/60, Malviya Nagar, Jaipur (Raj.)-302 017

Contact : 09414074020, 09829051363, 0141-2521969, Email: omegatesthouse@gmail.com

TEST REPORT

Sample Name	Sample No.C-2 Water Anu Asha WTP (Outlet)	Sample Code	2403840
Report No.	OTH/RN-20242488	Report Issue date	30/03/2024
ULR No.	TC733124000002488F	Page No.	01 OF 01
Reference to Sampling	NA	Sample Collected By	Customer

Customer Name & Address:		Sample Receiving Date:	22/03/2024
Siyag Builders, H-28, Kanta Khaturia Colony, Bikaner. (Raj.)		Date of Testing	23/03/2024
		Date of Completion	28/03/2024
		Sample Qty. & Condition	1 Ltr. & Ok
Environmental Conditions Under which test performed	Room Temperature	Registration No.	RAJ.1713/012971

Appearance: - Clear Colorless Liquid. Having some suspended particles.

CHEMICAL ANALYSIS

S.No.	Parameters	Results	Test Method	Units	Limits IS : 10500/2012 Desirable Limit/ Rejection Limit
1.	Odor	Agreeable	IS : 3025 (P-5)	NA	Agreeable
2.	Turbidity	Nil	IS : 3025 (P-10)	NTU	1 Max./5 Max
3.	pH	7.94	IS : 3025 (P-11)	NA	6.5 to 8.5
4.	Total Dissolved Solids	220	IS : 3025 (P-16)	mg/l.	500 Max. / 2000 Max.
5.	Total Hardness as CaCO ₃	156.14	IS : 3025 (P-21)	mg/l.	200 Max./ 600 Max.
6.	Chloride as Cl	46.28	IS : 3025 (P-32)	mg/l.	250 Max./ 1000 Max.
7.	Iron as Fe	BDL(<0.01)	IS : 3025 (P-53)	mg/l.	0.3 Max./ No relaxation
8.	Fluoride as F	0.15	IS : 3025 (P-60)	mg/l.	1.0 Max./ 1.5 Max.

MICROBIOLOGICAL ANALYSIS


1.	E.coli./ 100 ml	Absent/100 ml	IS : 15185-2016	Present or Absent/100 ml	Shall not be detectable in any 100ml of sample
2.	Coliform/ 100 ml	Absent/100 ml	IS : 15185-2016	Present or Absent/100 ml	Shall not be detectable in any 100ml of sample

Note: - 1.BDL- Below Detection Limit, NA- Not Applicable

2. The results relate only to items tested.

3. The information about the sample provided by customer.

END OF REPORT



NOTE:

- (1.) The result listed refer only to the tested sample and applicable parameters. Endorsement of products is neither inferred nor implied.
- (2.) Total liability of our concern is limited to the invoiced amount.
- (3.) The report is not to be reproduced wholly or in part and cannot be used as an evidence in the court of law and should not be used in any advertising media without our special permission in writing.